

Notice to Installer: Instructions must remain with installation.

ZT0553_EC

0422

Supersedes

1121

Trusted. Tested. Tough[®]

Product information presented here reflects conditions at time of publication. Consult factory regarding discrepancies or inconsistencies.



Visit our website:
www.zoellerpumps.com

Register your
Zoeller Pump Company
Product on our website:
<http://reg.zoellerpumps.com/>



HIGH WATER ALARM FOR QWIK JON[®] CHOICE

INSTRUCTIONS FOR USE

DESCRIPTION: The **QWIK ALARM[®]** by Zoeller is a self-contained electronic device that sounds an alarm when the metal strips of the sensor come in contact with water. The alarm is powered by four (4) AAA batteries and features an audible low battery alarm by emitting a short beep periodically.

INSTALLATION

1. Open the top cover and remove the carbon filter to access the circuit board with battery holder sleeve. Remove the circuit board from the battery holder sleeve and insert four AAA batteries into the battery container.
2. Reinstall the circuit board and battery container into the battery holder sleeve ensuring that the brass clips on the side of the circuit board contact the brass strips on the side of the battery holder sleeve.
3. Activate the alarm by setting the slide switch on the circuit board to L for low volume or H for high volume.
4. Slide the battery holder sleeve down the main body and ensure the brass contact strips touch the contact pins of the main body.
5. Test the **QWIK ALARM[®]** by immersing the sensor strips in water. You will hear three beeps every 5 seconds. This indicates that the unit is working properly.
6. To silence alarm, simply remove the sensor strips from the water and let them dry. Blowing air across the sensor leads will remove any residual moisture that may still be on them.
7. Remove the vent valve and its pipe seal on the **QWIK JON[®] CHOICE** unit and replace it with the **QWIK ALARM[®]**. The pipe seal may have to be slid halfway down the length of alarm and set in the opening before the alarm is inserted all the way in. A lubricant such as soapy water may be used.

MAINTENANCE

- a) Test your **QWIK ALARM[®]** every 3 months and, if necessary, clean the silver color water level sensor contact area to ensure proper operation.
- b) Under normal circumstances the four AAA batteries should provide approximately one year of service. **REPLACE YOUR BATTERIES AT LEAST ONCE A YEAR** to ensure proper operation. NOTE: Damp locations or high temperature may reduce the battery life.
- c) The alarm will sound one beep every 30 seconds if the battery is low. Please change the batteries.

LIMITED WARRANTY

Zoeller Pump Company warrants, to the purchaser and subsequent owner during the warranty period, every new Zoeller Pump Company product to be free from defects in material and workmanship under normal use and service, when properly installed, used and maintained, for a period of one year from date of installation or 18 months from date of manufacturer, whichever comes first. Parts that fail, (within one year of installation or 18 months of manufacturer, whichever comes first) that inspections determine to be defective in material or workmanship, will be repaired, replaced or remanufactured at Zoeller Pump Company's option, provided however, that by so doing we will not be obligated to replace an entire assembly, the entire mechanism or the complete unit. No allowance will be made for shipping charges, damages, labor or other charges that may occur due to product failure, repair or replacement.

This warranty does not apply to any material that has been disassembled without prior approval of Zoeller Pump Company, subjected to misuse, misapplication, neglect, alteration, accident or act of nature; that has not been installed, operated or maintained in accordance with Zoeller Pump Company installation instructions; that has been exposed to but not limited to the following: sand, gravel, cement, mud, tar, hydrocarbons or hydrocarbon derivatives (oil, gasoline, solvents, etc), wash towels or feminine sanitary products, etc. or other abrasive or corrosive substances. This warranty is in lieu of all other warranties expressed or implied; and we do not authorize any representative or other person to assume for us any other liability in connection with our products.

In those instances where damages are incurred as a result of an alleged pump failure, the Homeowner must retain possession of the pump for investigation purposes.

Contact Zoeller Pump Company, Services.Asia@zoeller.com Attention: Customer Support Department to obtain any needed repair or replacement of part(s) or additional information pertaining to our warranty.

ZOELLER PUMP COMPANY EXPRESSLY DISCLAIMS LIABILITY FOR SPECIAL, CONSEQUENTIAL OR INCIDENTAL DAMAGES OR BREACH OF EXPRESSED OR IMPLIED WARRANTY; AND ANY IMPLIED WARRANTY OF FITNESS FOR A PARTICULAR PURPOSE AND OF MERCHANTABILITY SHALL BE LIMITED TO THE DURATION OF THE EXPRESSED WARRANTY.

Some states do not allow limitations on the duration of an implied warranty, so the above limitation may not apply to you. Some states do not allow the exclusion or limitation of incidental or consequential damages, so the above limitation or exclusion may not apply to you.

This warranty gives you specific legal rights and you may also have other rights which vary from state to state.

Original Instructions.

P/N 10-5089

安裝前務必詳讀說明書

Trusted. Tested. Tough®

文件僅供參考
若有任何修改
恕不另行通知

請至美國卓勒泵浦公司
官網完成您的產品註冊



Visit our website:
www.zoellerpumps.com



QWIK JON® CHOICE 通氣閥高水位警報器

使用說明：

說明：卓勒提供之通氣閥高水位警報器 QWIK ALARM® 為獨立的電子裝置，當其感測器的金屬探條與水接觸時會發出嗶嗶警報聲。此警報器由四個 AAA 鹼性電池供電，具有間歇發出短促嗶聲，低電池聲音警報器特色。

安裝

1. 打開上蓋，取出破濾棉和帶電池座套的電路板。從電池座套上取下電路板，將四個 AAA 大小的電池放入電池盒中。
2. 將電路板和電池盒裝回電池座套筒，確保電路板側面的黃銅夾與電池座套筒側面的黃銅條接觸。
3. 將電路板上的滑動開關設置為 L 為小聲或 H 為大聲來啟動警報器。
4. 將電池座套放入主體，確保黃銅接觸條接觸主體的觸針。
5. 將感應條浸入水中來測試 QWIK ALARM®。每 5 秒您將聽到三聲嗶嗶聲。這表示設備運作正常。
6. 要使警報靜音，只需將感應條從水中取出並晾乾即可。用空氣吹過感測器探條將去除可能仍然存在於感應器上的任何殘留的水分
7. 拆下 QWIK JON® CHOICE 裝置上的通氣閥及其管道密封件，並將其更換為 QWIK ALARM®。在將警報器完全插入之前，管道密封件可能必須滑下警報器長度的一半並壓進開口中。可以使用潤滑劑，例如肥皂水。

維護

- a) 每三個月測試一次 QWIK ALARM®，如有必要，清潔水位感測器接觸點區域以確保正常運行。
- b) 在正常情況下，四個 AAA 電池應可提供一年的服務。至少每年更換一次電池以確保正常運行。注意：潮濕的地方或高溫可能會縮短電池壽命。
- c) 如果電池電壓低，每 30 秒您將聽到一聲嗶聲。請更換電池。

有限的保固

卓勒泵浦公司對於保固期間的購買者及後續擁有者，在產品正常裝、使用、維護及保養情況下所發生的材料及製造瑕疵，將免費提供新的卓勒泵浦公司產品。此保固期限為安裝日起算一年，或從製造日起算18個月，先到日期為主。發生故障之零件（安裝日後一年或製造日後18個月，以先到日期為主），經檢查確定為材料或製造疵者，將由卓勒泵浦公司進行修理、更換或重新製造。但即便如此，我們並無義務更換整個組件，整個機構或整個裝置。有關產品因故障，修理或更換所發生的運費、損壞、勞資或其他費用等並不提供額外津貼。

本保固不適用於以下情況：未經卓勒泵浦公司事先核准所拆解的任何材料、錯誤使用、不當使用、人為疏忽、改裝、意外或天然災害；或未依照卓勒泵浦公司說明書的說明所進行的安裝、操作或護等。將產品暴露於(但不限於)以下情況：沙中、砂礫、水泥、泥漿、焦油、碳氫化合物或碳氫化合物之衍生物（油、汽油、溶劑等）、清洗毛巾或女性衛生用品等或其他具有摩擦性或腐蝕性的物質中。本保固替代所有其他明示性或暗示性之保固；且我們未授權任何代表或其他人針對我們的產品代表我們執行任何其他法律責任。

在因涉嫌產品故障而招致損害的情況下，財產擁有人必須保留該產品以供查之用。

請聯絡卓勒泵浦公司：Services.Asia@zoeller.com，並洽：客戶支援部門以取得任何所需的零件修理或更換，或有關保固的更多資訊。卓勒泵浦公司對於特殊、衍生性或附帶性的損害賠償；違反明示性或暗示性的保固，將明示免責，且針對某特定目的之適用性的任何暗示性保固及商品適售性，應受限於其明示性保固期間。

有些地方並不容許暗示性保固期間的限制，因此以上限制可能不適用於您。有些地方不容許附帶性賠償或衍生性賠償的排他性或限制，因此以上的限制或排他性可能不適用於您。

此保固提供您特定的法律權利，但也可能因各地方法律規定而變更相關權利。

安装前务必详读说明书

Trusted. Tested. Tough®

文件仅供参考
若有任何修改
恕不另行通知

请至美国卓勒水泵公司
官网完成您的产品注册



Visit our website:
www.zoellerpumps.com



QWIK JON® CHOICE 通气阀高水位报警器

使用说明:

说明: 卓勒提供之通气阀高水位报警器 QWIK ALARM® 为独立的电子装置, 当其感测器的金属探条与水接触时会发出哔哔警报声。此报警器由四个 AAA 硷性电池供电, 具有间歇发出短促哔声, 低电池声音报警器特色。

安装

1. 打开上盖, 取出碳滤棉和带电池座套的电路板。从电池座套上取下电路板, 将四个 AAA 大小的电池放入电池盒中。
2. 将电路板和电池盒装回电池座套筒, 确保电路板侧面的黄铜夹与电池座套筒侧面的黄铜条接触。
3. 将电路板上的滑动开关设置为 L 为小声或 H 为大声来启动报警器。
4. 将电池座套放入主体, 确保黄铜接触条接触主体的触针。
5. 将感应条浸入水中来测试 QWIK ALARM®。每 5 秒您将听到三声哔哔声。这表示设备运作正常。
6. 要使警报静音, 只需将感应条从水中取出并晾乾即可。用空气吹过传感器探条将去除可能仍然存在于感应器上的任何残留的水分
7. 拆下 QWIK JON® CHOICE 装置上的通气阀及其管道密封件, 并将其更换为 QWIK ALARM®。在将报警器完全插入之前, 管道密封件可能必须滑下报警器长度的一半并压进开口中。可以使用润滑剂, 例如肥皂水。

维护

- a) 每三个月测试一次 QWIK ALARM®, 如有必要, 清洁水位传感器接触点区域以确保正常运行。
- b) 在正常情况下, 四个 AAA 电池应可提供一年的服务。至少每年更换一次电池以确保正常运行。注意: 潮湿的地方或高温可能会缩短电池寿命。
- c) 如果电池电压低, 每 30 秒您将听到一声哔声。请更换电池。

有限的保固

卓勒水泵公司对于保固期间的购买者及后续拥有者, 在产品正常装、使用、维护及保养情况下所发生的材料及制造瑕疵, 将免费提供新的卓勒水泵公司产品。此保固期限为安装日起算一年, 或从制造日起算18个月, 先到日期为主。发生故障之零件 (安装日后一年或制造日后18个月, 以先到日期为主), 经检查如果确定为材料或制造问题的, 将由卓勒水泵公司进行修理、更换或重新制造。但即便如此, 我们并无义务更换整个组件, 整个机构或整个装置。有关产品因故障, 修理或更换所发生的运费、损坏、劳资或其他费用等并不提供额外津贴。

本保固不适用于以下情况: 未经卓勒水泵公司事先核准所拆解的任何材料、错误使用、不当使用、人为疏忽、改装、意外或天然灾害; 或未依照卓勒水泵公司说明书的说明所进行的安装、操作或护等。将产品暴露于(但不限于)以下情况: 沙中、砂砾、水泥、泥浆、焦油、碳氢化合物或碳氢化合物之衍生物 (油、汽油、溶剂等)、清洗毛巾或女性卫生用品等或其他具有摩擦性或腐蚀性的物质中。本保固替代所有其他明示性或暗示性之保固; 且我们未授权任何代表或其他人针对我们的产品代表我们执行任何其他法律责任。

在因涉嫌产品故障而招致损害的情况下, 财产拥有人必须保留该产品以供查之用。

请联络卓勒水泵公司: Services.Asia@zoeller.com, 并洽: 客户支援部门以取得任何所需的零件修理或更换, 或有关保固的更多资讯。卓勒水泵公司对于特殊、衍生性或附带性的损害赔偿: 违反明示性或暗示性的保固, 将明示免责, 且针对某特定目的之适用性的任何暗示性保固及商品适售性, 应受限于其明示性保固期间。

有些地方并不容许暗示性保固期间的限制, 因此以上限制可能不适用于您。有些地方不容许附带性赔偿或衍生性赔偿的排他性或限制, 因此以上的限制或排他性可能不适用于您。

此保固提供您特定的法律权利, 但也可能因各地方法律规定而变更相关权利。